

March 9, 2017

Mr. Ronald Wybraniec  
 New Jersey Department of Children and Families  
 50 East State Street  
 Trenton, NJ 08608

RE: Lead in Water Sampling  
 New Jersey Department of Children and Families (NJDCF) Mercer Campus  
 & Mercer Police Station  
 1600 Stuyvesant Avenue & 1610 Stuyvesant Avenue  
 Trenton, New Jersey  
**Whitman Project #16-11-49T**

Dear Mr. Wybraniec:

The potable drinking water sampling, which consisted of 12 cold faucet samples and a laboratory blank sample were collected from the Mercer Campus by Sheila Innella of Whitman on February 20, 2017. Additionally, one (1) cold faucet sample and a laboratory blank sample were collected from the Police Station. First draw samples were collected from all sampling locations, in accordance with the USEPA and NJDEP protocols. All water samples and associated laboratory blanks were transported to Precision Analytical Services, Inc. located in Toms River, New Jersey for analysis. All sample analysis was performed utilizing the USEPA test method "Lead and Copper in Water by Furnace AAS (EPA 200.9)".

Lead was not detected in samples collected from both facilities. Sampling results for the Mercer Campus and the Police Station are summarized below and are provided as an attachment to this letter.

School	Location	ug/L
Mercer Campus	Kitchen cold faucet	ND
	Room 103 cold faucet	ND
	Room 101 cold faucet	ND
	Room 102 cold faucet	ND
	Room 104 cold faucet	ND
	Staff Room cold faucet	ND
	Room 105 cold faucet	ND
	Room 106 cold faucet	ND
Room 107 cold faucet	ND	

Ronald Wybraniec  
New Jersey Division of Children and Families  
March 10, 2017  
Page 2

Mercer Campus	Room 110 cold faucet	ND
	Room 109 cold faucet	ND
	Room 108 cold faucet	ND
	N/A (Laboratory Blank)	ND
Mercer Police Station	Kitchen cold faucet	ND
	N/A (Laboratory Blank)	ND

Should you have any questions or require additional information, please feel free to contact our office at 732-390-5858.

Very truly yours,



Mark E. Hasting  
Director

MEH/  
Attachment