



Corporate Headquarters
7 Pleasant Hill Road
Cranbury, NJ 08512

Tel: 732.390.5858 • Fax: 732.390.9496
www.whitmanco.com

March 9, 2017

Mr. Ronald Wybraniec
New Jersey Department of Children and Families
50 East State Street
Trenton, NJ 08608

RE: Lead in Water Sampling
New Jersey Department of Children and Families (NJDCF) Ocean Campus
1141 Old Freehold Road
Toms River, New Jersey
Whitman Project #16-11-49T

Dear Mr. Wybraniec:

The potable drinking water sampling, which consisted of seven (7) cold faucet samples and a laboratory blank sample, was conducted by Sheila Innella of Whitman on February 20, 2017. First draw samples were collected from all sampling locations, in accordance with the USEPA and NJDEP protocols. All water samples and associated laboratory blanks were transported to Precision Analytical Services, Inc. located in Toms River, New Jersey for analysis. All sample analysis was performed utilizing the USEPA test method "Lead and Copper in Water by Furnace AAS (EPA 200.9)".

The samples collected from the Ocean Campus were found to be either not detected (ND) or below the action level of 15.0 ppb established by the USEPA and the NJDEP. Sampling results are summarized below and are provided as an attachment to this letter.

School	Location	ug/L
Ocean Campus	Staff Lounge (Room 105) cold faucet	ND
	Kitchen (Room 103) cold faucet	ND
	Room 106 cold faucet	ND
	Room 108 cold faucet	0.488 J
	Room 111 cold faucet	ND
	Room 112 cold faucet	ND
	Room 115 cold faucet	ND
	N/A (Laboratory Blank)	ND

Creating Solutions. Exceeding Expectations.

Ronald Wybraniec
New Jersey Division of Children and Families
March 10, 2017
Page 2

Should you have any questions or require additional information, please feel free to contact our office at 732-390-5858.

Very truly yours,



Mark E. Hasting
Director

MEH/
Attachment