



## CERTIFICATE OF ANALYSIS

Customer : Whitman  
7 Pleasant Hill Road  
Cranbury, NJ 08512

Project ID : Union Campus  
PAS Project ID : P17-0858

Matrix : Drinking Water  
Report Date : 3/8/2017

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P17-0858-01	01-UC-RM 108-BU	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 08:00	2/27/17 11:13
P17-0858-02	02-UC-RM 105-BU	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 08:05	2/27/17 11:21
P17-0858-03	03-UC-RM 106-BU	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 08:06	2/27/17 11:38
P17-0858-04	04-UC-RM 107-BU	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 08:07	2/27/17 11:51
P17-0858-05	05-UC-RM 109-BU	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 08:09	2/27/17 11:55
P17-0858-06	06-UC-RM 110-BU	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 08:10	2/27/17 11:59
P17-0858-07	07-UC-KITCHEN-BU	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 08:11	2/27/17 12:03
P17-0858-08	08-UC-BREAK RM-BU	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 08:12	2/27/17 12:08
P17-0858-09	09-UC-RM 104-BU	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 08:13	2/27/17 12:12
P17-0858-10	10-UC-RM 103-BU	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 08:14	2/27/17 12:16
P17-0858-11	11-UC-RM 102-BU	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 08:16	2/27/17 12:20
P17-0858-12	12-UC-RM 101-BU	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 08:17	2/27/17 12:25
P17-0858-13	13-UC-FIELD BLANK-BU	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 08:18	2/27/17 12:38

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit

MDL = Minimum Detection Limit

MCL = Maximum Contaminant Level

DF = Dilution Factor

ND = Analyzed for but not detected

B = Compound found in blank and samples

E = Concentration exceeds calibration range

J = Estimated result

\* Federal Action Level

All samples are analyzed in accordance with  
New Jersey Department of Environmental  
Protection Protocol

Mark D. Feitelson, Lab. Director