

March 9, 2017

Mr. Ronald Wybraniec
 New Jersey Department of Children and Families
 50 East State Street
 Trenton, NJ 08608

RE: Lead in Water Sampling
 New Jersey Department of Children and Families (NJDCF) Cherry Hill Campus
 39 Evesham Road West
 Cherry Hill, New Jersey
Whitman Project #16-11-49T

Dear Mr. Wybraniec:

The potable drinking water sampling, which consisted of 14 cold faucet samples and a laboratory blank sample, was conducted by Liz Casterlin of Whitman on February 20, 2017. First draw samples were collected from all sampling locations, in accordance with the USEPA and NJDEP protocols. All water samples and associated laboratory blanks were transported to Precision Analytical Services, Inc. located in Toms River, New Jersey for analysis. All sample analysis was performed utilizing the USEPA test method "Lead and Copper in Water by Furnace AAS (EPA 200.9)".

The samples collected from the Cherry Hill Campus were found to be either ND or below the action level of 15.0 ppb established by the USEPA and the NJDEP. Below is a summary of the results. Sampling results are summarized below and are provided as an attachment to this letter.


School	Sample Location	Result (ug/L)
Cherry Hill Campus	Room 113 cold faucet	7.31
	Room 114 cold faucet	ND
	Room 108 cold faucet	ND
	Room 107 cold faucet	ND
	Room 117 cold faucet	4.93
	Room 118 cold faucet	1.04 J
	Room 120 cold faucet	ND
	Room 122 cold faucet	7.61
	Room 119 cold faucet	11.5
	Room 121 cold faucet	ND

Ronald Wybraniec
New Jersey Division of Children and Families
March 10, 2017
Page 2

Cherry Hill Campus	Room 128 cold faucet	ND
	Room 127 cold faucet	ND
	Room 123 cold faucet	ND
	Staff Room (Room 104) cold faucet	ND
	N/A (Laboratory Blank)	ND

Should you have any questions or require additional information, please feel free to contact our office at 732-390-5858.

Very truly yours,



Mark E. Hasting
Director

MEH/
Attachment