

DOCKET NO. D-2009-026 CP-4

DELAWARE RIVER BASIN COMMISSION

Discharge to a Tributary of Special Protection Waters

**Wallenpaupack Area School District
Wastewater Treatment Plant
Palmyra Township, Pike County, Pennsylvania**

PROCEEDINGS

This docket is issued in response to an application submitted to the Delaware River Basin Commission (DRBC or Commission) on June 1, 2020 (Application), for renewal of the docket holder's existing wastewater treatment plant (WWTP) and its discharge. The discharge is permitted by the Pennsylvania Department of Environmental Protection (PADEP) in National Pollutant Discharge Elimination System (NPDES) Permit No. PA0031364.

The Application was reviewed for continuation of the project in the Comprehensive Plan and approval under Section 3.8 of the *Delaware River Basin Compact*. The Pike County Planning Commission has been notified of pending action. A public hearing on this project was held by the DRBC on May 12, 2021.

A. DESCRIPTION

- 1. Purpose.** The purpose of this docket is to renew approval of the docket holder's existing 0.04 million gallons per day (mgd) WWTP and its discharge.
- 2. Location.** The docket holder's WWTP is in Palmyra Township, Pike County, Pennsylvania between Lake Wallenpaupack Road and Lake Wallenpaupack. The WWTP will continue to discharge to Lake Wallenpaupack on the Wallenpaupack Creek, which is a tributary to the Lackawaxen River, at River Mile 277.7– 15.8 – 1.4 – 0.2 (Delaware River – Lackawaxen River – Wallenpaupack Creek – Lake Wallenpaupack) via Outfall No. 001, within the drainage area of the Upper Delaware River Special Protection Waters (SPW).

Specific location information has been withheld for security reasons.

- 3. Area Served.** The docket holder's WWTP will continue to receive wastewater flows from the Wallenpaupack Area School District (WASD) High School, Middle School, North Primary School, and the North Intermediate School. The WWTP also receives wastewater flows from PPL Corporation's Wilsonville Camping Area, PPL Corporation's Wallenpaupack Environmental Learning Center, and the Pocono Mountain Vacation Bureau Visitor Center. The WWTP's service area is located in Palmyra Township, Pike County, Pennsylvania.

For the purpose of defining the Area Served, Section B (Type of Discharge) and D (Service Area) of the docket holder's Application are incorporated herein by reference, to the extent consistent with all other conditions contained in the DECISION Section of this docket.

4. **Design Criteria.** The docket holder's 0.04 mgd WWTP utilizes an extended aeration activated sludge treatment system paired with sand filtration.

5. **Facilities.** The existing WWTP facilities consist of a grinder, a bar screen, a flow equalization tank, followed by two (2) extended aeration package plants in parallel, each containing an aeration tank, a clarifier, and a sand filter, followed by chlorine disinfection, and post aeration. The WWTP also includes aerobic sludge digestion and chemical addition for nutrient removal.

The docket holder's WWTP discharges to waters classified as SPW and is required to have available standby power. The docket holder indicated in the Application that the existing WWTP has available standby power.

The docket holder's WWTP is not staffed 24 hours per day and shall have a remote alarm system that continuously monitors plant operations in accordance with the Commission's SPW requirements. The docket holder indicated in the Application that the existing WWTP has a remote alarm system installed that continuously monitors plant operations.

The docket holder has prepared and implemented an emergency management plan (EMP) for the existing wastewater treatment facility in accordance with Commission SPW requirements.

The project facilities are not located in the 100-year flood zone.

Wasted sludge will continue to be hauled off-site by a licensed hauler for disposal at a state-approved facility.

6. **Water Withdrawals.** The potable water supply in the project service area is provided by wells owned and operated by WASD and individual, privately-owned wells. The wells are operated at rates below the DRBC review threshold.

7. **NPDES Permit / DRBC Effluent Requirements.** NPDES Permit No. PA0031364 was issued by the PADEP on August 23, 2017 and includes final effluent limitations for the project discharge of 0.04 mgd to surface waters classified by the PADEP as supporting High-Quality Cold Water Fishes (HQ-CWF). EFFLUENT TABLE C-1 included in Section C. DECISION Condition C.1. of this docket contains effluent requirements for DRBC parameters that must be met as a condition of this approval. Effluent requirements for Outfall No. 001 are based on a discharge rate of 0.04 mgd.

8. **Relationship to the Comprehensive Plan.** The project was added to the Comprehensive Plan via the approval of Docket No. D-2009-026 CP-1 on September 21, 2011 and modified via Docket No. D-2009-026 CP-2 on April 15, 2015. The project was continued in Docket No. D-2009-026 CP-3 which was approved on September 14, 2016. Issuance of this docket will continue the discharge project in the Comprehensive Plan.

B. **FINDINGS**

The purpose of this docket is to renew the approval of the docket holder's existing 0.04 mgd WWTP. No modifications to the WWTP are proposed.

1. **Special Protection Waters**

In 1992, the DRBC adopted Special Protection Waters (SPW) requirements, as part of the DRBC *Water Quality Regulations (WQR)*, designed to protect existing water quality in applicable areas of the Delaware River Basin. One hundred twenty miles of the Delaware River from Hancock, New York downstream to the Delaware Water Gap has been classified by the DRBC as SPW. This stretch includes the sections of the river federally designated as "Wild and Scenic" in 1978 -- the Upper Delaware Scenic and Recreational River and the Delaware Water Gap National Recreation Area -- as well as an eight-mile reach between Milrift and Milford, Pennsylvania which is not federally designated. The SPW regulations apply to this 120-mile stretch of the river and its drainage area.

On July 16, 2008, the DRBC approved amendments to its *WQR* that provide increased protection for waters that the Commission classifies as SPW. The portion of the Delaware River and its tributaries within the boundary of the Lower Delaware River Management Plan Area was approved for SPW designation.

The docket holder's WWTP discharges to the drainage area to the Upper Delaware SPW. The docket holder's WWTP discharge is required to comply with the SPW requirements, as outlined in Article 3.10.3A.2. of the *WQR*.

Article 3.10.3A.2.e.1). and 2). of the Commission's *WQR* states that projects subject to review under Section 3.8 of the *Compact* that are located in the drainage area of SPW must submit for approval a Non-Point Source Pollution Control Plan (NPSPCP) that controls the new or increased non-point source loads generated within the portion of the docket holder's service area which is also located within the drainage area of SPW. The service area of the docket holder is located within in the drainage area to the SPW. Since this project does not entail additional construction and expansion of facilities/service area and there are not any new or increased non-point source loads associated with this approval, the NPSPCP requirement is not applicable at this time. Accordingly, Section C. DECISION Condition C.4. has been included in this docket.

2. Other Findings

At the docket holder's WWTP discharge, Wallenpaupack Creek has an estimated seven-day low flow with a recurrence interval of ten years (Q_{7-10}) of 11.7 mgd (18.1 cfs). The ratio of this low flow to the hydraulic design wastewater discharge from the 0.04 mgd WWTP is 290 to 1.

The nearest surface water intake of record for public water supply is located on the Delaware River approximately 110 River Miles downstream of the docket holder's WWTP and is operated by City of Easton's Water Treatment Plant.

The project does not conflict with the Comprehensive Plan and is designed to prevent substantial adverse impact on the water resources related environment, while sustaining the current and future water uses and development of the water resources of the Basin.

The effluent limits in the NPDES Permit conform with Commission effluent quality requirements, where applicable.

The project is designed to produce a discharge meeting the effluent requirements as set forth in the Commission's *WQR*.

C. DECISION

Effective on the approval date for Docket No. D-2009-026 CP-4 below, the project described in Docket No. D-2009-026 CP-3 is removed from the Comprehensive Plan to the extent that they are not included in Docket No. D-2009-026 CP-4; Docket No. D-2009-026 CP-3 is terminated and replaced by Docket No. D-2009-026 CP-4; and the project and the appurtenant facilities described in Section A. DESCRIPTION of this docket shall be continued in the Comprehensive Plan. The project and appurtenant facilities as described in Section A of this docket are approved pursuant to Section 3.8 of the *Compact*, subject to the following conditions:

Monitoring and Reporting

1. The docket holder shall comply with the requirements contained in the EFFLUENT TABLES below. The docket holder shall submit the required monitoring results electronically to the DRBC Project Review Section via email aemr@drbc.state.nj.us on the **Annual Effluent Monitoring Report Form** located at this web address: <http://www.state.nj.us/drbc/programs/project/pr/info.html>. The monitoring results shall be submitted annually, absent any observed limit violations, by January 31. If a DRBC effluent limit is violated, the docket holder shall submit the result(s) to the DRBC within 30 days of the violation(s) and provide a written explanation that states the action(s) the docket holder has taken to correct the violation(s) and protect against any future violations. The following average monthly effluent limits are among those listed in the NPDES Permit and meet or are more stringent than the effluent requirements of the DRBC.

EFFLUENT TABLE C-1: DRBC Parameters Included in NPDES Permit

OUTFALL 001 (Discharge to Lake Wallenpaupack)		
PARAMETER	LIMIT	MONITORING
pH (Standard Units)	6 to 9 at all times	As required by NPDES permit
Dissolved Oxygen	7.0 mg/l (minimum at all times)	As required by NPDES permit
CBOD (5-Day at 20° C)	85 mg/l 85% minimum removal	As required in the NPDES permit
BOD5 (Influent)	Monitor and Report	As required in the NPDES permit
Total Suspended Solids	30 mg/l	As required in the NPDES permit
Total Dissolved Solids	1,000 mg/l*	As required in the NPDES permit
Fecal Coliform (5-1 to 9-30) (10-1 to 4-30)	200 colonies per 100 ml as a geo. avg. 2,000 colonies per 100 ml as a geo. avg.	As required in the NPDES permit
Ammonia-Nitrogen (5-1 to 10-31) (11-1 to 4-30)	3.0 mg/l 9.0 mg/l	As required in the NPDES permit
Nitrate-Nitrite as Nitrogen	Monitor and Report	As required by NPDES permit
Total Nitrogen	Monitor and Report	As required by NPDES permit
Total Phosphorus	0.5 mg/l	As required by NPDES permit

* See DECISION Condition C.5.

2. The docket holder is responsible for timely submittal to the DRBC of a docket renewal application on the appropriate application form including the appropriate docket application filing fee (see 18 CFR 401.43) at least 6 months in advance of the docket expiration date set forth below. The docket holder will be subject to late filed renewal surcharges in the event of untimely submittal of its renewal application, whether or not DRBC issues a reminder notice in advance of the deadline or the docket holder receives such notice. In the event that a timely and complete application for renewal has been submitted and the DRBC is unable, through no fault of the docket holder, to reissue the docket before the expiration date below, the terms and conditions of the current docket will remain fully effective and enforceable against the docket holder pending the grant or denial of the application for docket approval.

Other Conditions

3. Except as otherwise authorized by this docket, if the docket holder seeks relief from any limitation based upon a DRBC water quality standard or minimum treatment requirement, the docket holder shall apply for approval from the Executive Director or for a docket revision in accordance with Section 3.8 of the Compact and the Rules of Practice and Procedure.

4. Prior to allowing connections from any new service areas, the docket holder shall either submit and have approved by the Executive Director of the DRBC a NPSPCP in accordance with Section 3.10.3.A.2.e or receive written confirmation from the Executive Director of the DRBC that the new service area is in compliance with a DRBC-approved NPSPCP.
5. The docket holder may request of the Executive Director in writing the substitution of specific conductance for TDS. The request should include information that supports the effluent specific correlation between TDS and specific conductance. Upon review, the Executive Director may modify the docket to allow the substitution of specific conductance for TDS monitoring.
6. The docket holder is permitted to treat and discharge wastewater as set forth in the Area Served Section of this docket, which incorporates by reference Sections B (Type of Discharge) and D (Service Area) of the docket holder's Application to the extent consistent with all other conditions of this DECISION Section.
7. The docket holder is prohibited from treating/pre-treating any hydraulic fracturing wastewater from sources in or out of the Basin at this time. Should the docket holder wish to treat/pre-treat hydraulic fracturing wastewater in the future, the docket holder will need to first apply to the Commission to renew this docket and be issued a revised docket allowing such treatment and an expanded service area. Failure to obtain this approval prior to treatment/pre-treatment will result in action by the Commission.
8. The facility and operational records shall be available at all times for inspection by the DRBC.
9. The facility shall be operated at all times to comply with the requirements of the Commission's *WQR*.
10. If at any time the receiving treatment plant proves unable to produce an effluent that is consistent with the requirements of this docket approval, no further connections shall be permitted until the deficiency is remedied.
11. Nothing herein shall be construed to exempt the docket holder from obtaining all necessary permits and/or approvals from other State, Federal or local government agencies having jurisdiction over this project.
12. The docket holder shall discharge wastewater in such a manner as to avoid injury or damage to fish or wildlife and shall avoid any injury to public or private property.
13. No sewer service connections shall be made to newly constructed premises with plumbing fixtures and fittings that do not comply with water conservation performance standards contained in Resolution No. 88-2 (Revision 2).
14. The issuance of this docket approval shall not create any private or proprietary rights in the waters of the Basin, and the Commission reserves the right to amend, suspend or rescind the docket for cause, in order to ensure proper control, use and management of the water resources of the Basin.

- 15.** The docket holder shall be subject to applicable DRBC regulatory program fees, in accordance with duly adopted DRBC resolutions and/or regulations (see 18 CFR 401.43).
- 16.** This approval is transferable by request to the DRBC Executive Director provided that the project purpose and area served approved by the Commission in this docket will not be materially altered because of the change in project ownership. The request shall be submitted on the appropriate form and be accompanied by the appropriate fee (see 18 CFR 401.43).
- 17.** The docket holder shall request a name change of the entity to which this approval is issued if the name of the entity to which this approval is issued changes its name. The request for name change shall be submitted on the appropriate form and be accompanied by the appropriate fee (see 18 CFR 401.43).
- 18.** The Executive Director may modify or suspend this approval or any condition thereof, or require mitigating measures pending additional review, if in the Executive Director's judgment such modification or suspension is required to protect the water resources of the Basin.
- 19.** Any person who objects to a docket decision by the Commission may request a hearing in accordance with Article 6 of the Rules of Practice and Procedure. In accordance with Section 15.1(p) of the *Delaware River Basin Compact*, cases and controversies arising under the *Compact* are reviewable in the United States district courts.

BY THE COMMISSION

APPROVAL DATE: June 9, 2021

EXPIRATION DATE: August 31, 2027